

48" PIPE - 54" PIPE

PIPE DIA. (IN)		PIPE TYPE	CIRCULAR PIPE COVER HEIGHTS IN FEET ③																																		
			2-5	5-10	10-15	15-20	20-25	25-30	30-35	35-40	40-45	45-50	50-55	55-60	60-65	65-70	70-75	75-80	80-85	85-90	90-95	95-100	100-105	105-110	110-115	115-120											
48	2⅔" x ½" CSPHS ①	14 GA.								12 GA.				10 GA.																							
	2⅔" x ½" CSPLS ①	14 GA.						12 GA.																													
	2⅔" x ½" CAPHS	12 GA.								10 GA.				8 GA.																							
	SRS ①	14 GA.						12 GA.																													
	SRA	12 GA.						10 GA.																													
	PVC	RIBBED (PROFILE WALL)																																			
	HDPE																																				
	RCP ⑨																																				
54	2⅔" x ½" CSPHS ①	14 GA.						12 GA.				10 GA.																									
	2⅔" x ½" CSPLS ①	14 GA.				12 GA.																															
	3"x1" CSPHS ①	14 GA.								12 GA.				10 GA.																							
	3"x1" CSPLS ①	14 GA.				12 GA.		10 GA.				8 GA.																									
	5"x1" CSPHS ①	14 GA.						12 GA.				10 GA.																									
	2⅔" x ½" CAPHS	12 GA.						10 GA.				8 GA.																									
	3"x1" CAPHS	14 GA.						12 GA.				10 GA.				8 GA.																					
	SRS ①	14 GA.				12 GA.																															
	SRA	12 GA.				10 GA.																															
	⑦	RCP ⑨																																			
		2-5	5-10	10-15	15-20	20-25	25-30	30-35	35-40	40-45	45-50	50-55	55-60	60-65	65-70	70-75	75-80	80-85	85-90	90-95	95-100	100-105	105-110	110-115	115-120												

~ NOTES ~

- ① GAGES FOR CORRUGATED STEEL PIPE ITEMS SHOWN ARE BASED ON ALUMINUM-COATED TYPE 2 STEEL AS PER AASHTO M-274. ALUMINUM COATED TYPE 2 STEEL IS ONLY PERMITTED IN Ph RANGES OF 5 TO 9.
2. WHEN CORRUGATED STEEL PIPE IS ZINC COATED (GALVANIZED) THE GAGE SHALL BE ONE GAGE HEAVIER THAN SHOWN IN THE TABLES.
- ③ SEE CUR. STD. DWG. RDI-001 FOR EXPLANATION OF COVER HEIGHTS LESS THAN 2 FEET.
4. CSP, CAP, SRS AND SRA ARE SHOWN IN GAGE.
5. MAXIMUM COVER HEIGHT MEASURED FROM TOP OF PIPE TO SUBGRADE ELEVATION SHALL GOVERN GAGE OF PIPE TO BE USED FOR ENTIRE LENGTH OF PIPE INSTALLATION.
6. ALL CIRCULAR STRUCTURAL PLATE SHALL BE 5% VERTICALLY ELONGATED.
- ⑦ 54" DIA. PIPE IS MINIMUM SIZE FOR COVER HEIGHTS GREATER THAN 65 FEET.
8. SEE CUR. STD. DWG. RDI-035 FOR COATINGS, LININGS AND PAVINGS FOR NON-STRUCTURAL PIPE.
- ⑨ SEE CUR. STD. DWGS. RDI-021 AND RDI-026 FOR RCP COVER HEIGHT AND BEDDING REQUIREMENTS.

USE WITH CUR. STD. DWGS.
RDI-001 RDI-021 RDI-026
RDI-035

LEGEND

- CSPHS: CORRUGATED STEEL PIPE WITH HELICAL LOCK SEAM OR HELICAL WELDED SEAM (HELICAL CORR.)
- CSPLS: CORRUGATED STEEL PIPE WITH LONGITUDINAL RIVETED OR SPOT WELDED SEAM (ANNULAR CORR.)
- CAPHS: CORRUGATED ALUMINUM ALLOY PIPE WITH HELICAL LOCK SEAM (HELICAL CORR.)
- HDPE: HIGH DENSITY POLYETHYLENE PIPE
- PVC: POLYVINYL CHLORIDE
- SRS: SPIRAL RIB STEEL
- SRA: SPIRAL RIB ALUMINUM
- RCP: CIRCULAR REINFORCED CONCRETE PIPE

DRAINAGE

REVISION DATE: 12/01/2015
REVISION NUMBER: 0

12-01-2015
DATE

SUBMITTED
DIVISION DIRECTOR

12-01-2015
DATE

APPROVED
STATE HIGHWAY ENGINEER



COMMONWEALTH OF KENTUCKY
DEPARTMENT OF HIGHWAYS



PIPES

CULVERT AND STORM SEWER PIPE TYPES AND COVER HEIGHTS

STANDARD DRAWING NUMBER
RDI-003-05