

SIZE		NO. 5 STEEL BARS								
		BAR s		BAR t		BAR u		BAR v		LBS.
X	Y	QTY.	LIN. FT.	QTY.	LIN. FT.	QTY.	LIN. FT.	QTY.	LIN. FT.	
3'-0"	2'-0"	-	-	-	-	-	-	-	-	7
	2'-6"	4	3'-6"	6	4'-0"			14	0'-10"	59
	3'-0"		4'-0"	8					1'-4"	77
	3'-6"		4'-6"	10					1'-10"	94
	4'-0"		5'-0"	12					2'-4"	112
	4'-6"		5'-6"	14					2'-10"	130
	5'-0"		6'-0"	16					3'-4"	147
3'-6"	2'-0"	4	3'-0"	4	4'-6"	-	-	-	-	38
	2'-6"		3'-6"	6				14	0'-10"	62
	3'-0"		4'-0"	8					1'-4"	81
	3'-6"		4'-6"	10					1'-10"	100
	4'-0"		5'-0"	12					2'-4"	118
	4'-6"		5'-6"	14					2'-10"	137
	5'-0"		6'-0"	16					3'-4"	156
4'-0"	2'-0"	8	3'-0"	4	5'-0"	20	0'-10"	-	-	70
	2'-6"		3'-6"	6				14	0'-10"	97
	3'-0"		4'-0"	8					1'-4"	119
	3'-6"		4'-6"	10					1'-10"	141
	4'-0"		5'-0"	12					2'-4"	163
	4'-6"		5'-6"	14					2'-10"	185
	5'-0"		6'-0"	16					3'-4"	207
4'-6"	2'-0"	8	3'-0"	4	5'-6"	20	1'-1"	-	-	78
	2'-6"		3'-6"	6				14	0'-10"	105
	3'-0"		4'-0"	8					1'-4"	128
	3'-6"		4'-6"	10					1'-10"	151
	4'-0"		5'-0"	12					2'-4"	174
	4'-6"		5'-6"	14					2'-10"	197
	5'-0"		6'-0"	16					3'-4"	220
5'-0"	2'-0"	12	3'-0"	4	6'-0"	20	1'-4"	-	-	97
	2'-6"		3'-6"	6				14	0'-10"	127
	3'-0"		4'-0"	8					1'-4"	154
	3'-6"		4'-6"	10					1'-10"	180
	4'-0"		5'-0"	12					2'-4"	207
	4'-6"		5'-6"	14					2'-10"	233
	5'-0"		6'-0"	16					3'-4"	259

- ~ NOTES ~
- IN ADDITION TO THE CHARTED STEEL, FOUR "L" BARS ARE REQUIRED IN THE LID AND ARE INCLUDED IN THE TOTALS.
 - CONCRETE QUANTITIES FOR LID ARE INCLUDED ON "DIMENSIONS AND ESTIMATE OF QUANTITIES (PIPE CHAMBER)"; SEE CUR. STD. DWG. RDB-410.
 - REINFORCEMENT SHALL HAVE A CLEAR DISTANCE OF 2" FROM THE OUTSIDE FACE UNLESS OTHERWISE SHOWN.
- USE WITH CUR. STD. DWGS.
RDB-271 RDB-272 RDB-400
RDB-410 RDB-420 RDB-270

